



नवी मुंबई
महानगरपालिका

Navi Mumbai
Municipal Corporation

पर्यावरण प्रयोगशाळा
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/106/2023-2024

Date : 12/12/2023

Date of sample received. : 12/12/2023

Date of sample testing : 12/12/2023 to 14/12/2023

Customer's Name and Location : Tilak Education Society
Plot No. 21&22, Sector - 5
Ghansoli, Navi Mumbai


TEST REPORT


Sr. No.	Testing Parameter	Test Result	Test Standards (IS 10500 : 2012)
01	pH	7.3	6.5 - 8.5
02	Turbidity	0.0	Max. 5.0 N.T.U.
03	Residual Chlorine	0.1	Min. 0.2 mg/l
04	Bacteriological Test		
	Total Coliforms	0	0 per 100 ml
	E. Coli	- ve	- ve
	F. Coli	- ve	- ve

Test Report No. : 106

Date : 14/12/2023

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.


Lab Chemist

Lab Incharge

Environment Laboratory
Navi Mumbai Municipal Corporation



नवी मुंबई
महानगरपालिका

Navi Mumbai



मुलगी वाचवा,देश वाचवा

Municipal Corporation

आरोग्य विभाग, तिसरा मजला, नमुंमपा मुख्यालय,
से.15ए सि.बी.डी. नवी मुंबई 400 614
दूरध्वनी क्र : 27567261

Health Dept. 3rd floor. N.N.M.C.Head Office,
Sec. 15A CBD NAVI MUMBAI - 400 614
Tel No. 27567261

No.NMMC/Health/ 305 /2024

Date -: 11 / 1 / 2024

To,
The President
Tilak education Society,
Plot No. 21 & 22, Sector 5, Ghansoli
Navi Mumbai

Sub:-About Safe Drinking Water Certificate

Ref- 1.Your application no. 1089,dated 11.01.2024

2. Report Of water Sample dated 14.12.2023

As per Your Application regarding safe drinking water facilities and hygienic sanitary conditions Tilak education Society, Plot No. 21 & 22, Sector 5, Ghansoli Navi Mumbai water sample report submitted by you on 11.01.2024, it is understood that drinking water facilities are as per norms.

This certificate is issued for period of one year from the date of this certificate provided norms prescribed by the State Govt are maintained.

Dr. Prashant Jawade
Medical Officer of Health
Navi Mumbai Municipal Corporations